

7 JAN 1982

MEMORANDUM FOR THE RECORD

SUBJECT: Meeting with Skidmore, Owings & Merrill on Test
Borings Report and Environmental Assessment []

STAT
STAT

1. On 22 December 1981, a meeting was held in the Washington office of Skidmore, Owings & Merrill (SOM) to discuss the referenced subjects. The following persons were present:

[] , SOM
SOM
Dames & Moore
Dames & Moore
PS/OL
OL

STAT

2. The Building Planning Staff, Office of Logistics (BPS/OL) advised that the Agency had reviewed the test boring report prepared by Dames & Moore and that except for two minor clarifications, the report was satisfactory. It was agreed that the report's reference to a "three level" parking garage should read "four level" and that the indicated top and bottom elevation levels of the garage were correct. A missing water level reading for boring DM-1 was supplied by [] shortly following the meeting.

STAT

3. BPS/OL stated that the Fairfax County reviewing comments would probably contain reference to the disposal of some 355,000 cubic yards of dirt and noted that only a third of this amount was for the actual building excavation. SOM commented on the design concepts that required the additional excavation and stated that they felt the concepts were still valid and justified the excavation. It was agreed that some excavation material could be distributed on site and that a disposal plan was properly the responsibility of the construction contractor and not the architect-engineer or the Agency.

Page Denied